



## Fire Cloak™ EV Fire Blanket – Storage, Inspection and Warranty

### Storage:

The Fire Cloak™ EV Fire Blanket should be stored in the protective carry bag provided.

To prevent mechanical damage, we recommend that the Fire Cloak™ EV Fire Blanket, (in its protective carry bag) should be stored in a heavy-duty wall mounted, or mobile box which are available as an optional extra.

The fabric and coating of the Fire Cloak™ are extremely stable across a wide range of humidity and temperature conditions. Ideally the Fire Cloak™ should be stored out of direct sunlight in a cool dry place and temperature should be in the range of 10°C to 35°C - (15°F to 95°F).

### Inspection:

The Fire Cloak™ EV Fire Blanket should be inspected every 24 months to check for signs of mechanical damage, holes, tears etc.

A large area, up to 15 x 12 metres (50 x 40ft) will be needed if the Fire Cloak™ EV Fire Blanket is completely unfolded on a clean floor. Alternatively, the inspection can be carried out by unfolding on a long bench in sections.

After inspection, the Fire Cloak™ EV Fire Blanket should be refolded with “Z” folds every 70cm (2ft 4ins) and the retaining strap refastened, so that it can easily be repacked in the protective carry bag.

**IMPORTANT:** “Z” (or concertina) folding is essential as this ease’s deployment in an emergency.

### Warranty:

The Fire Cloak™ EV Fire Blanket is warranted for 5 years from date of purchase, although it will likely be effective for an indefinite period if stored correctly.

The Fire Cloak™ EV Fire Blanket has been exhaustively tested to international fire resistance standards, which includes:


**BS476:** Part 6:1989+A1:2009 and Part 7:1997 – **CLASS 0 attained, similar to Class A in the USA.**

**ASTM D6413-22** – Vertical Flame Resistance - **PASSED**

**FMVSS 302** – Federal Motor Vehicle Fire Safety Standard - **PASSED**

**NFPA 701** – Flame Propagation of Textiles – **PASSED**

**ISO EN 13502-1 2018:** A2, s1, d0

Fire Cloak™ is proudly -  **MADE IN  
BRITAIN**