

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** QEP Australia Pty Ltd  
68 Prosperity Way

**Test Number :** 23-000156  
**Issue Date :** 10/02/2023  
**Print Date :** 10/02/2023

South Dandenong VIC 3175

**Sample Description** Clients Ref : 8mm Water Resistant Floorselect Laminate Flooring"  
Laminate flooring planks  
Colour : Timber look  
End Use : Flooring  
Nominal Composition : High density fibreboard core, decorative layer and stabilisation backing  
Nominal Mass per Unit Area/Density : 880kg/m3  
Nominal Thickness : 8mm



288836

62460

Page 1 of 2

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



Chris Campbell

APPROVED SIGNATORY

  
MICHAEL A. JACKSON B.Sc.(Hons)  
MANAGING DIRECTOR

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

Client : QEP Australia Pty Ltd  
68 Prosperity Way

Test Number : 23-000156  
Issue Date : 10/02/2023  
Print Date : 10/02/2023

South Dandenong VIC 3175

### AS ISO 9239.1-2003

#### Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source

Date of Sample Arrival 16-01-2023

Date Tested 10-02-2023

CHF Value	1	2	3	Mean
Length	7.5	7.1	7.3	7.3 kW/m <sup>2</sup>
Width	8.6	-	-	- kW/m <sup>2</sup>

HF-30 Value	1	2	3	Mean
Length	8.6	8.1	7.9	8.2 kW/m <sup>2</sup>
Width	9.2	-	-	- kW/m <sup>2</sup>

Smoke Value	1	2	3	Mean
Length	53	30	17	33 % .min
Width	12	-	-	- % .min

Blistering Yes

Each specimen was clamped to a substrate of 6mm thick fibre reinforced cement board prior to testing.

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

288836

62460

Page 2 of 2

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



Chris Campbell

APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)  
MANAGING DIRECTOR